

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Independent LED controlgears

Name and address of the applicant

MEAN WELL Enterprises Co., Ltd.
No.28, Wuquan 3rd Rd, Wugu District, New Taipei City 24891, Taiwan

Name and address of the manufacturer

MEAN WELL Enterprises Co., Ltd.
No.28, Wuquan 3rd Rd, Wugu District, New Taipei City 24891, Taiwan

Name and address of the factory

MEAN WELL (GUANGZHOU) Electronics Co., Ltd.
No.11 Jingu South Road, Huadu District, 510890 Guangzhou Guangdong, China*When more than one factory* [Additional information on page 2](#)

Ratings and principal characteristics

Product dataRatings: 100-240 Vac, 0,95 A, 50/60 Hz, IP67,
Class II, ta: 40 °C, tc: 70 °C, λ: 0,95, independent SELV,
thermal protect: 110 °C, constant voltage type
Other information sees model list in General Product Information of test report.

Trademark / Brand (if any)



MEAN WELL

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

LPF-90x-y

Additional information

 [Additional information on page 2](#)

A sample of the product was tested and found to be in conformity with

IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014 and IEC 61347-2-13:2014/AMD1:2016


National differences:

AU, EU Group Differences, EU Special National Conditions, GB, JP, NZ

As shown in the Test Report Ref. No. which forms part of this Certificate

4931712.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2025-01-23

Signature: Miranda Zhou



Ref. Certif. No.

NL-114171

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

Additional factory

YONGDEN TECHNOLOGY CORPORATION
345 MacArthur HighWay, Tabang, 3015 Guiguinto, Bulacan, Philippines

MEAN WELL Enterprises Co., Ltd.
No.28, Wuquan 3rd Rd, Wugu District, New Taipei City 24891, Taiwan

SuZhou MEAN WELL Technology Co., Ltd.
No.269, Changping Road, Huangdai Town, Xiangcheng District, 215152 Suzhou Jiangsu, China

MEAN WELL INDIA ELECTRONICS PRIVATE LIMITED
9C, Peenya industrial area, Chokkasandra, 2ND PHASE, PEENYA, 560058 Bengaluru (BANGALORE) Urban,
Karnataka, India

Additional information

Model/Type reference:

LPF-90x-y

The "x" in the model name can be D or blank to denote with dimming function (D) or without (blank);
the "y" in the model name can be 15, 20, 24, 30, 36, 42, 48 or 54 to denote output voltage in volt.

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands



Date: 2025-01-23

Signature: Miranda Zhou