



Test Report : MDS02L-15

2W SIP Package DC-DC Medical Grade Unregulated Converter

■ DESIGN VERIFY TEST

Output Function Test

Input Function Test

Protection Function Test

■ SAFETY TEST

Safety Test

■ RELIABILITY TEST

Environment Test

Other Test

DESIGN VERIFY TEST
OUTPUT FUNCTION TEST

NO	TEST ITEM	SPECICATION	TEST CONDITION	RESULT	VERDICT
1	VOLTAGE ACCURACY	-5%~+5% (Max)	I/P:5VDC O/P:FULL LOAD Ta:25°C	+2.00%	P
2	RIPPLE & NOISE	75 mVp-p (Max)	I/P:5VDC O/P:FULL LOAD Ta:25°C	45mV	P
3	LINE REGULATION	-12% ~ +12% (Typ)	I/P:4.5VDC-5.5VDC O/P:FULL LOAD Ta:25°C	-10.85% ~ +10.93%	P
4	LOAD REGULATION	-10% ~ +10% (Max)	I/P:5VDC O/P:MINI LOAD-FULL LOAD Ta:25°C	-3.05% ~ +3.14%	P

INPUT FUNCTION TEST

NO	TEST ITEM	SPECICATION	TEST CONDITION	RESULT	VERDICT
1	EFFICIENCY	79 % (Typ)	I/P:5VDC O/P:FULL LOAD Ta:25°C	79.64%	P
2	DC CURRENT	510 mA / FULL LOAD (Max) 65 mA / NO LOAD (Max)	I/P:5VDC O/P:NO / FULL LOAD Ta:25°C	502.6mA / FULL LOAD 62.4mA / NO LOAD	P

PROTECTION FUNCTION TEST

NO	TEST ITEM	SPECICATION	TEST CONDITION	RESULT	VERDICT
1	SHORT PROTECTION	MOMENTARY 3sec. max	I/P:5VDC O/P:FULL LOAD Ta:25°C	NO DAMAGE OK	P

SAFETY TEST
SAFETY TEST

NO	TEST ITEM	SPECICATION	TEST CONDITION	RESULT	VERDICT
1	WITHSTAND VOLTAGE	I/P-O/P:6000 VDC/min	I/P-O/P:6000 VDC/min Ta:25°C	I/P-O/P: 0.002mA NO DAMAGE	P

2	ISOLATION RESISTANCE	I/P-O/P:500VDC>100MΩ	I/P-O/P:500 VDC Ta:25°C	I/P-O/P>100MΩ NO DAMAGE	P
---	----------------------	----------------------	----------------------------	----------------------------	---

■ RELIABILITY TEST

ENVIRONMENT TEST

NO	TEST ITEM	SPECICATION	TEST CONDITION	RESULT	VERDICT								
1	TEMPERATURE RISE TEST	1. ROOM AMBIENT BURN-IN : 8 HRS I/P:5VDC O/P:FULL LOAD Ta=25°C 2. HIGH AMBIENT BURN-IN : 8 HRS I/P:5VDC O/P:FULL LOAD Ta=85°C			P								
		<table border="1"> <thead> <tr> <th>NO</th> <th>Position</th> <th>1</th> <th>2</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>CASE</td> <td>44.5°C</td> <td>104.9°C</td> </tr> </tbody> </table>		NO	Position	1	2	1	CASE	44.5°C	104.9°C		
NO	Position	1	2										
1	CASE	44.5°C	104.9°C										
2	LOW TEMPERATURE TURN ON TEST	TURN ON AFTER 2 HOURS	I/P:5VDC O/P: FULL LOAD Ta= -40°C	TEST : OK	P								

OTHER

NO	TEST ITEM	SPECICATION	TEST CONDITION	RESULT	VERDICT
1	MTBF	MIL-HDBK-217F,GB,25°C,Full Load TOTAL FAILURE RATE : 0.243962 M.T.B.F : 4099000 HRS			P

TEST RESULT	TESTER	APPROVAL
PASS	ARCHEN	VINCENT ZENG