



Ref. Certif. No.

**DK-176283-UL**

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

**CB TEST CERTIFICATE**

Product

Switching Power Supply

Name and address of the applicant

MEAN WELL ENTERPRISES CO., LTD.  
No 28 Wuquan 3rd Rd, Wugu District New Taipei City 24891  
Taiwan

Name and address of the manufacturer

MEAN WELL ENTERPRISES CO., LTD.  
No 28 Wuquan 3rd Rd, Wugu District New Taipei City 24891  
Taiwan

Name and address of the factory

MEAN WELL ENTERPRISES CO., LTD.  
No 28 Wuquan 3rd Rd  
Wugu District  
New Taipei City  
24891  
Taiwan

*Note: When more than one factory, please report on page 2*

☒ Additional Information on page 2

Ratings and principal characteristics

NSP-750-5  
Input: 100-240Vac, 10-4.0A, 50/60Hz  
277V ac, 3.5A, 50/60Hz  
Output: +5Vdc, 100A

☒ Additional Information on page 3

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

CTF Stage 2

Model / Type Ref.

NSP-750-xzzzz

☒ Additional Information on page 2

Additional information (if necessary may also be reported on page 2)

The risk management requirements of the standard were not addressed  
National Differences: CA, EU Group Differences, JP, US

☒ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60601-1:2005, IEC 60601-1:2005/AMD1:2012,  
IEC 60601-1:2005/AMD2:2020

As shown in the Test Report Ref. No. which forms part of this Certificate

E227340-D6012-CB-1 issued on 2026-01-28

This CB Test Certificate is issued by the National Certification Body



☐ UL Solutions (US), 333 Pfingsten Rd IL 60062, Northbrook, USA  
☒ UL Solutions (Denko), Borupvang 5A DK-2750 Ballerup, DENMARK  
☐ UL Solutions (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN  
☐ UL Solutions (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see [www.ul.com/ncbnames](http://www.ul.com/ncbnames)

Date: 2026-01-29

Signature:

Thomas Wilson



Ref. Certif. No.

**DK-176283-UL**

**Factory(ies):**

Suzhou Mean Well Technology Co Ltd  
No.269, Changping Road  
Huangdai Town Xiangcheng District  
Suzhou  
Jiangsu 215152  
China

MEAN WELL (Guangzhou) Electronics Co Ltd  
No 11 Jingu South Road  
Huadu District  
Guangzhou  
Guangdong 510890  
China

MEAN WELL INDIA ELECTRONICS PRIVATE LIMITED  
9c Peenya Industrial Area Chokkasandra 2nd Phase  
Peenya  
Bengaluru (Bangalore) Urban Karnataka 560058  
India

YONGDEN TECHNOLOGY CORP  
345 Macarthur Hwy  
Tabang  
Guiguinto 3015 Bulacan  
Philippines

**Additional Model Detail(s):**

NSP-750-xzzzz, (x=5, 12, 15, 24, 27, 36, 48, 60, each z=may be blank, -, 0~9, A~Z, a~z for market purpose)

**Additionally evaluated to:**

EN 60601-1:2006, EN 60601-1:2006/A1:2013, EN 60601-1:2006/A12:2014, EN 60601-1:2006/A2:2021,  
EN 60601-1:2006/A13:2024

**Additional information (if necessary)**



- ☐ UL Solutions (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- ☒ UL Solutions (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- ☐ UL Solutions (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- ☐ UL Solutions (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see [www.ul.com/ncbnames](http://www.ul.com/ncbnames)

Date: 2026-01-29

Signature:

Thomas Wilson



Ref. Certif. No.

**DK-176283-UL**

**Additional Ratings:**

NSP-750-12

Input: 100-240Vac, 10-4.0A, 50/60Hz  
277V ac, 3.5A, 50/60Hz  
Output: +12Vdc, 62.5A

NSP-750-15

Input: 100-240Vac, 10-4.0A, 50/60Hz  
277V ac, 3.5A, 50/60Hz  
Output: +15Vdc, 50A

NSP-750-24

Input: 100-240Vac, 10-4.0A, 50/60Hz  
277V ac, 3.5A, 50/60Hz  
Output: +24Vdc, 31.3A

NSP-750-27

Input: 100-240Vac, 10-4.0A, 50/60Hz  
277V ac, 3.5A, 50/60Hz  
Output: +27Vdc, 27.8A

NSP-750-36

Input: 100-240Vac, 10-4.0A, 50/60Hz  
277V ac, 3.5A, 50/60Hz  
Output: +36Vdc, 20.9A

NSP-750-48

Input: 100-240Vac, 10-4.0A, 50/60Hz  
277V ac, 3.5A, 50/60Hz  
Output: +48Vdc, 15.7A

NSP-750-60

Input: 100-240Vac, 10-4.0A, 50/60Hz  
277V ac, 3.5A, 50/60Hz  
Output: +60Vdc, 12.6A

**Additional information (if necessary)**



- ☐ UL Solutions (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- ☒ UL Solutions (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- ☐ UL Solutions (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- ☐ UL Solutions (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see [www.ul.com/ncbnames](http://www.ul.com/ncbnames)

Date: 2026-01-29

Signature:

Thomas Wilson