



Test Report: RCB-1600-24

1600W Rack Mountable Front End Battery Charger

■ DESIGN VERIFY TEST

Output Function Test

Input Function Test

Protection Function Test

Control Function Test

Component Stress Test

■ SAFETY & E.M.C. TEST

Safety Test

E.M.C. Test

■ RELIABILITY TEST

ENVIRONMENT TEST

■ DESIGN VERIFY TEST

OUTPUT FUNCTION TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT
1	BOOST CHARGE VOLTAGE(Vboost)(default)	Default, programmable 28.8V±0.24V	I/P: 230 VAC O/P: CV MODE Ta:25°C	28.859V
2	FLOAT CHARGE VOLTAGE	Default, programmable 27.6V±0.24V	I/P: 230 VAC O/P: CV MODE Ta:25°C	27.646V
3	OUTPUT CURRENT	55A±1.65A	I/P: 230 VAC O/P:CV MODE-2V Ta:25°C	55.5A
4	VOLTAGE ADJ. RANGE	23.5V~30V DIP switch position 4 : OFF	I/P: 230 VAC O/P:NO LOAD Ta:25°C	22.6V~30.72V/230VAC 22.6V~30.72V/115VAC
5	LEAKAGE CURRENT FROM BATTERY (Typ.)	<45mA	I/P: AC OFF O/P:BATTERY Ta:25°C	42.6mA

INPUT FUNCTION TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT
1	INPUT VOLTAGE RANGE	90VAC~264VAC	I/P:TESTING O/P: FULL LOAD O/P:60% LOAD Ta:25°C	150 V~ 264 V 87V~264V
			I/P: (1)LOW-LINE-3V=87 V HIGH-LINE+15%=300 V O/P:FULL/MIN LOAD (PLEASE CHECK DERATING CURVE) ON: 30 Sec OFF: 30 Sec 10MIN (2)230Vac ON: 0.5 Sec OFF: 0.5 Sec 20MIN (3)230Vac ON:3Sec OFF:3Sec 12HOURS (POWER ON/OFF NO DAMAGE)	TEST:OK
2	INPUT FREQUENCY RANGE	47HZ ~63 HZ NO DAMAGE	I/P:100 VAC ~264 VAC O/P:FULL~MIN LOAD Ta:25°C	TEST: OK
3	INPUT CURRENT (Typ.)	230V/ 8.5 A 115V/ 15 A	I/P : 230 VAC I/P : 115 VAC O/P : FULL LOAD Ta : 25°C	I =7.83A/ 230VAC I =12.77A/ 115VAC
4	LEAKAGE CURRENT	<1.5 mA / 230 VAC	I/P : 230 VAC O/P : Min LOAD Ta : 25°C	L-FG : 0.8 mA N-FG : 0.8 mA
5	POWER FACTOR (Typ.)	0.97 / 230VAC	I/P : 230 VAC O/P : FULL LOAD Ta : 25°C	PF=0.98/230VAC



6	EFFICIENCY(Typ.)	92%	I/P:230 VAC O/P:FULL LOAD Ta:25°C	92.46 %
7	INRUSH CURRENT(Typ.)	230V/35 A COLD START	I/P : 230 VAC O/P : FULL LOAD Ta : 25°C	I =31.6A/ 230VAC T50= 1920 us/230V
<p>INPUT=230VAC/50HZ @ FULL LOAD CH1 : Input current</p>				

PROTECTION FUNCTION TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT
1	OVER VOLTAGE PROTECTION	31.5 V~ 37.5 V PROTECTION TYPE : Shut down o/p voltage, re-power on to recover	I/P: 264VAC I/P: 230VAC I/P: 90VAC O/P:MIN LOAD Ta:25°C	34.5V/ 264VAC 34.5V/ 230VAC 34.5V/ 90VAC PROTECTION TYPE : Shut down o/p voltage, re-power on to recover
2	OVER TEMPERATURE PROTECTION	NO DAMAGE PROTECTION TYPE : Shut down o/p voltage, recovers automatically after temperature goes down	I/P: 264VAC I/P: 90VAC O/P:FULL LOAD	O.T.P. Active PROTECTION TYPE : Shut down o/p voltage, recovers automatically after temperature goes down

CONTROL FUNCTION TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT								
1	AUXILIARY POWER (AUX)	1. 5V±10%@0.3A ripple:150mVp-p 2. 12V±10%@0.8A ripple:250mVp-p	I/P: 230 VAC O/P:FULL LOAD Ta:25°C	4.741V/0.3A ; ripple:14mVp-p 11.36V/0.8A ; ripple: 156 mVp-p								
2	REMOTE ON/OFF CONTROL	<p>The charger can be turned ON/OFF individually or along with other units in parallel by using the "Remote ON-OFF" function.</p> <table border="1" style="margin-left: auto; margin-right: auto;"> <thead> <tr> <th>Between Remote ON-OFF and +5V-AUX</th> <th>Charger Status</th> </tr> </thead> <tbody> <tr> <td>Switch Short</td> <td>ON</td> </tr> <tr> <td>Switch Open</td> <td>OFF</td> </tr> </tbody> </table> <p>I/P: 230 VAC O/P:FULL LOAD Ta:25°C</p> <table border="1" style="width: 100%; margin-top: 10px;"> <tr> <td>Between ON/OFF and +5V-AUX</td> <td>OUTPUT</td> </tr> </table>			Between Remote ON-OFF and +5V-AUX	Charger Status	Switch Short	ON	Switch Open	OFF	Between ON/OFF and +5V-AUX	OUTPUT
Between Remote ON-OFF and +5V-AUX	Charger Status											
Switch Short	ON											
Switch Open	OFF											
Between ON/OFF and +5V-AUX	OUTPUT											

		<table border="1"> <tr> <td>SW SHORT</td> <td>ON</td> </tr> <tr> <td>SW OPEN</td> <td>OFF</td> </tr> </table>	SW SHORT	ON	SW OPEN	OFF																																			
SW SHORT	ON																																								
SW OPEN	OFF																																								
3	ALARM SIGNAL	<p>1. DC OK SIGNAL High (4.5 ~ 5.5V) : When the $V_{out} \leq 8V/16V/32V \pm 1V$. Low (0 ~ 0.5V) : When $V_{out} \geq 8V/16V/32V \pm 1V$. The maximum sourcing current is 10mA and only for output. DC OK is associated with battery low protection. I/P: 230 VAC O/P: FULL LOAD Ta: 25°C Test Result :</p> <table border="1"> <thead> <tr> <th>Vout</th> <th>DC OK SIGNAL</th> </tr> </thead> <tbody> <tr> <td>$V_{out} \leq 75\%$</td> <td>4.985V</td> </tr> <tr> <td>$V_{out} \geq 85\%$</td> <td>-0.09V</td> </tr> </tbody> </table> <p>2. T-ALARM</p> <table border="1"> <thead> <tr> <th>P.S.U STATUS</th> <th>Vo</th> <th>T-ALARM</th> </tr> </thead> <tbody> <tr> <td>NORMAL</td> <td>100%±2%</td> <td>-0.1 ~0.5V</td> </tr> <tr> <td>OTP OR FAN LOCK</td> <td>0V</td> <td>4.5-5.5V</td> </tr> </tbody> </table> <p>I/P: 230 VAC O/P: FULL LOAD Ta: 25°C Test Result :</p> <table border="1"> <thead> <tr> <th>P.S.U STATUS</th> <th>T-ALARM</th> </tr> </thead> <tbody> <tr> <td>NORMAL</td> <td>-0.09 V</td> </tr> <tr> <td>OTP OR FAN LOCK</td> <td>4.936V</td> </tr> </tbody> </table> <p>3. AC-OK</p> <table border="1"> <thead> <tr> <th>AC IN</th> <th>Vo</th> <th>AC OK</th> </tr> </thead> <tbody> <tr> <td>$AC I/P \geq 87V_{rms}$</td> <td>100%±2%</td> <td>4.5-5.5V</td> </tr> <tr> <td>$AC I/P \leq 75V_{rms}$</td> <td>0V</td> <td>0-0.5V</td> </tr> </tbody> </table> <p>I/P: TEST O/P: 60% LOAD Test Result :</p> <table border="1"> <thead> <tr> <th>AC IN</th> <th>Vo</th> <th>AC OK</th> </tr> </thead> <tbody> <tr> <td>$AC I/P \geq 87V$</td> <td>100.4%</td> <td>5.0489V</td> </tr> <tr> <td>$AC I/P \leq 75V$</td> <td>0.002V</td> <td>0.00V</td> </tr> </tbody> </table>	Vout	DC OK SIGNAL	$V_{out} \leq 75\%$	4.985V	$V_{out} \geq 85\%$	-0.09V	P.S.U STATUS	Vo	T-ALARM	NORMAL	100%±2%	-0.1 ~0.5V	OTP OR FAN LOCK	0V	4.5-5.5V	P.S.U STATUS	T-ALARM	NORMAL	-0.09 V	OTP OR FAN LOCK	4.936V	AC IN	Vo	AC OK	$AC I/P \geq 87V_{rms}$	100%±2%	4.5-5.5V	$AC I/P \leq 75V_{rms}$	0V	0-0.5V	AC IN	Vo	AC OK	$AC I/P \geq 87V$	100.4%	5.0489V	$AC I/P \leq 75V$	0.002V	0.00V
Vout	DC OK SIGNAL																																								
$V_{out} \leq 75\%$	4.985V																																								
$V_{out} \geq 85\%$	-0.09V																																								
P.S.U STATUS	Vo	T-ALARM																																							
NORMAL	100%±2%	-0.1 ~0.5V																																							
OTP OR FAN LOCK	0V	4.5-5.5V																																							
P.S.U STATUS	T-ALARM																																								
NORMAL	-0.09 V																																								
OTP OR FAN LOCK	4.936V																																								
AC IN	Vo	AC OK																																							
$AC I/P \geq 87V_{rms}$	100%±2%	4.5-5.5V																																							
$AC I/P \leq 75V_{rms}$	0V	0-0.5V																																							
AC IN	Vo	AC OK																																							
$AC I/P \geq 87V$	100.4%	5.0489V																																							
$AC I/P \leq 75V$	0.002V	0.00V																																							
4	OUTPUT VOLTAGE PROGRAMMABLE(PV)	<p>DIP switch position 4 : OFF ※ In addition to the adjustment via the built-in potentiometer, the output voltage can be trimmed to 75-125% of the nominal voltage by applying EXTERNAL VOLTAGE.</p>  <p>RCB-1600-48 RCB-1600-24 RCB-1600-12</p>  <p>I/P: 230 VAC O/P: FULL LOAD</p>																																							

		<p>Ta:25°C Test Result :</p> <table border="1"> <tr> <td>MODEL \ PV</td> <td><0.4V</td> <td>1V</td> <td>4.7V</td> <td>5V</td> </tr> <tr> <td>SPEC</td> <td>24V±5%</td> <td>18V±5%</td> <td>30V±5%</td> <td>30V±5%</td> </tr> <tr> <td>Vout</td> <td>24.11V</td> <td>18.03V</td> <td>30.2V</td> <td>30.3V</td> </tr> </table>	MODEL \ PV	<0.4V	1V	4.7V	5V	SPEC	24V±5%	18V±5%	30V±5%	30V±5%	Vout	24.11V	18.03V	30.2V	30.3V			
MODEL \ PV	<0.4V	1V	4.7V	5V																
SPEC	24V±5%	18V±5%	30V±5%	30V±5%																
Vout	24.11V	18.03V	30.2V	30.3V																
<p>5</p>	<p>OUTPUT CURRENT PROGRAMMABLE (PC)</p>	<p>DIP switch position 4 : OFF ※ The output current can be trimmed to 20~100% of the rated current by applying EXTERNAL VOLTAGE.</p> <p>I/P: 230 VAC O/P: TESTING Ta:25°C Test Result :</p> <table border="1"> <tr> <td>ADJ V</td> <td><0.4V</td> <td>1V</td> <td>4.7V</td> <td>5V</td> </tr> <tr> <td>SPEC</td> <td>100%±10%</td> <td>20%±10%</td> <td>100%±10%</td> <td>100%±10%</td> </tr> <tr> <td>Iout</td> <td>101%</td> <td>22.25%</td> <td>100.7%</td> <td>101.6%</td> </tr> </table>	ADJ V	<0.4V	1V	4.7V	5V	SPEC	100%±10%	20%±10%	100%±10%	100%±10%	Iout	101%	22.25%	100.7%	101.6%			
ADJ V	<0.4V	1V	4.7V	5V																
SPEC	100%±10%	20%±10%	100%±10%	100%±10%																
Iout	101%	22.25%	100.7%	101.6%																
<p>6</p>	<p>TEMPERATURE COMPENSATION</p>	<p>Temperature sense associated with the temperature compensation function.</p> <p>◎ To exploit the temperature compensation function, please attach the temperature sensor, NTC, to the battery or the battery's vicinity. ◎ The charger is able to work normally without the NTC.</p> <p>I/P: 230 VAC O/P: FULL LOAD Test Result :</p> <table border="1"> <thead> <tr> <th rowspan="2">TEMP</th> <th rowspan="2">Voltage compensation</th> <th colspan="2">Temperature compensation</th> </tr> <tr> <th>BEFORE</th> <th>AFTER</th> </tr> </thead> <tbody> <tr> <td>(Ta=0°C)</td> <td>28.8V = +0.90V ±0.24V</td> <td>29.082</td> <td>29.946</td> </tr> <tr> <td>(Ta=25°C)</td> <td>28.8V = 0V</td> <td>29.082</td> <td>29.082</td> </tr> <tr> <td>(Ta=50°C)</td> <td>28.8V = -0.90V ±0.24V</td> <td>29.084</td> <td>28.271</td> </tr> </tbody> </table>	TEMP	Voltage compensation	Temperature compensation		BEFORE	AFTER	(Ta=0°C)	28.8V = +0.90V ±0.24V	29.082	29.946	(Ta=25°C)	28.8V = 0V	29.082	29.082	(Ta=50°C)	28.8V = -0.90V ±0.24V	29.084	28.271
TEMP	Voltage compensation	Temperature compensation																		
		BEFORE	AFTER																	
(Ta=0°C)	28.8V = +0.90V ±0.24V	29.082	29.946																	
(Ta=25°C)	28.8V = 0V	29.082	29.082																	
(Ta=50°C)	28.8V = -0.90V ±0.24V	29.084	28.271																	

<p>7 Charging Curve</p>	<p>※ By factory default, this charger performs the default curve which can be programmed via PMBus. ※ To disable / enable the charging curve, change to a 2 stage curve, a different curve frequently used for certain types of batteries in the industry, and so on, please refer to the Installation Manual.</p> <p>⊙ Default 3 stage charging curve</p> <p>⊙ Embedded 3 stage charging curve</p> <table border="1"> <thead> <tr> <th>MODEL</th> <th>Description</th> <th>Vboost</th> <th>Vfloat</th> </tr> </thead> <tbody> <tr> <td rowspan="3">12V</td> <td>Default, programmable</td> <td>14.4</td> <td>13.8</td> </tr> <tr> <td>Pre-defined, gel batter</td> <td>14</td> <td>13.6</td> </tr> <tr> <td>Pre-defined, flooded battery</td> <td>14.2</td> <td>13.4</td> </tr> <tr> <td rowspan="3">24V</td> <td>Pre-defined, AGM battery</td> <td>14.5</td> <td>13.5</td> </tr> <tr> <td>Default, programmable</td> <td>28.8</td> <td>27.6</td> </tr> <tr> <td>Pre-defined, gel batter</td> <td>28</td> <td>27.2</td> </tr> <tr> <td rowspan="3">48V</td> <td>Pre-defined, flooded battery</td> <td>28.4</td> <td>26.8</td> </tr> <tr> <td>Pre-defined, AGM battery</td> <td>29</td> <td>27</td> </tr> <tr> <td>Default, programmable</td> <td>57.6</td> <td>55.2</td> </tr> <tr> <td></td> <td>Pre-defined, gel batter</td> <td>56</td> <td>54.4</td> </tr> <tr> <td></td> <td>Pre-defined, flooded battery</td> <td>56.8</td> <td>53.6</td> </tr> <tr> <td></td> <td>Pre-defined, AGM battery</td> <td>58</td> <td>54</td> </tr> </tbody> </table> <p>⊙ Suitable for lead-acid batteries (flooded, Gel and AGM) and Li-ion batteries (lithium iron and lithium manganese). I/P: 230 VAC O/P: FULL LOAD Test Result :</p> <table border="1"> <thead> <tr> <th>MODEL</th> <th>Constant voltage(V_{boost})</th> <th>Float (V_{float})</th> <th>Turn state current</th> </tr> </thead> <tbody> <tr> <td rowspan="2">24V</td> <td>28.8V± 0.24V</td> <td>27.6V± 0.24V</td> <td>5.5A± 1.65A</td> </tr> <tr> <td>28.859V</td> <td>27.646V</td> <td>5.6A</td> </tr> </tbody> </table>	MODEL	Description	Vboost	Vfloat	12V	Default, programmable	14.4	13.8	Pre-defined, gel batter	14	13.6	Pre-defined, flooded battery	14.2	13.4	24V	Pre-defined, AGM battery	14.5	13.5	Default, programmable	28.8	27.6	Pre-defined, gel batter	28	27.2	48V	Pre-defined, flooded battery	28.4	26.8	Pre-defined, AGM battery	29	27	Default, programmable	57.6	55.2		Pre-defined, gel batter	56	54.4		Pre-defined, flooded battery	56.8	53.6		Pre-defined, AGM battery	58	54	MODEL	Constant voltage(V _{boost})	Float (V _{float})	Turn state current	24V	28.8V± 0.24V	27.6V± 0.24V	5.5A± 1.65A	28.859V	27.646V	5.6A
MODEL	Description	Vboost	Vfloat																																																							
12V	Default, programmable	14.4	13.8																																																							
	Pre-defined, gel batter	14	13.6																																																							
	Pre-defined, flooded battery	14.2	13.4																																																							
24V	Pre-defined, AGM battery	14.5	13.5																																																							
	Default, programmable	28.8	27.6																																																							
	Pre-defined, gel batter	28	27.2																																																							
48V	Pre-defined, flooded battery	28.4	26.8																																																							
	Pre-defined, AGM battery	29	27																																																							
	Default, programmable	57.6	55.2																																																							
	Pre-defined, gel batter	56	54.4																																																							
	Pre-defined, flooded battery	56.8	53.6																																																							
	Pre-defined, AGM battery	58	54																																																							
MODEL	Constant voltage(V _{boost})	Float (V _{float})	Turn state current																																																							
24V	28.8V± 0.24V	27.6V± 0.24V	5.5A± 1.65A																																																							
	28.859V	27.646V	5.6A																																																							
<p>8 LED Status Indicators</p>	<p>※ LED Status Indicators</p> <table border="1"> <thead> <tr> <th>LED</th> <th>Description</th> </tr> </thead> <tbody> <tr> <td>● Green</td> <td>Float (stage 3)</td> </tr> <tr> <td>● Orange</td> <td>Charging (stage 1 or stage 2)</td> </tr> <tr> <td>● Red</td> <td>The LED will present a constant red light when the abnormal status (OTP, OLP, fan fail and charging timeout) arises.</td> </tr> <tr> <td>● Red (Flashing)</td> <td>The LED will flash with the red light when the internal temperature reaches 60°C; under this condition, the unit still operates normally without entering OTP. (In the meantime, an alarm signal will be sent out through the PMBus interface.)</td> </tr> </tbody> </table> <p>TEST : OK</p>	LED	Description	● Green	Float (stage 3)	● Orange	Charging (stage 1 or stage 2)	● Red	The LED will present a constant red light when the abnormal status (OTP, OLP, fan fail and charging timeout) arises.	● Red (Flashing)	The LED will flash with the red light when the internal temperature reaches 60°C; under this condition, the unit still operates normally without entering OTP. (In the meantime, an alarm signal will be sent out through the PMBus interface.)																																															
LED	Description																																																									
● Green	Float (stage 3)																																																									
● Orange	Charging (stage 1 or stage 2)																																																									
● Red	The LED will present a constant red light when the abnormal status (OTP, OLP, fan fail and charging timeout) arises.																																																									
● Red (Flashing)	The LED will flash with the red light when the internal temperature reaches 60°C; under this condition, the unit still operates normally without entering OTP. (In the meantime, an alarm signal will be sent out through the PMBus interface.)																																																									

COMPONENT STRESS TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT
1	PWM Transistor (D to S) or (C to E) Peak Voltage	Q901 Rated 29 A/650 V	I/P:High-Line +3V =267V AC ON/OFF VDS: O/P: (1)Full Load Ta:25°C	VDS: (1)469V
2	P.F.C Transistor (D to S) or (C to E) Peak Voltage	Q52 Rated 52 A/600 V	I/P:High-Line +3V =267 V AC ON/OFF O/P: (1)Full Load Ta:25°C	VDS: (1)464V
3	Diode Peak Voltage	Q101 Rated 104 A/150 V Q104 Rated 104 A/150 V	I/P:High-Line +3V =267 V AC ON/OFF O/P: (1)Full Load Ta:25°C	Q101: (1)101.2V Q104: (1)100.4V VDS: VDS:
4	Input Capacitor Voltage	C5 Rated: 680µ/400V SURGE VOLTAGE:450V	I/P:High-Line +3V =267 V O/P: (1)Full Load Ta:25°C	(1)398V
5	Control IC Voltage Test	PWM IC U901 Rated 6.5V ~24 V PFC IC U51 Rated 6V ~16V	I/P:High-Line +3V =267 V AC ON/OFF O/P(1)FULL LOAD Ta:25°C	U901 (1) 13.8V U51 (1)12.8 V

6	Transistor	Q154 Rated : 100A/40V	I/P:High-Line +3V =267 V (HOT SWAP TEST) O/P: (1)Full Load	(1)400mV
7	Transistor	Q163 Rated : 2.4A/100V	I/P:High-Line +3V =267 V (HOT SWAP TEST) O/P: (1)Full Load	(1)600mV

SAFETY TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT
1	WITHSTAND VOLTAGE	I/P-O/P: 3KVAC/min I/P-FG :2KVAC/min O/P-FG:1.5KVAC/min	I/P-O/P: 3.6 KVAC/min I/P-FG: 2.4 KVAC/min O/P-FG:1.8 KVAC/min Ta:25°C	I/P-O/P:6.77mA I/P-FG:7.63mA O/P-FG:5.84mA NO DAMAGE
2	ISOLATION RESISTANCE	I/P-O/P:500VDC>100MΩ I/P-FG: 500VDC>100MΩ O/P-FG:500VDC>100MΩ	I/P-O/P: 500 VDC I/P-FG: 500 VDC O/P-FG: 500 VDC Ta:25°C	I/P-O/P: 30GΩ I/P-FG: 30GΩ O/P-FG: 30GΩ NO DAMAGE
3	GROUNDING CONTINUITY	FG(PE) TO CHASSIS OR TRACE < 100 mΩ	40A / 2min Ta:25°C	17 mΩ

E.M.C TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT
1	HARMONIC	EN61000-3-2 CLASS A	I/P:230VAC/50HZ O/P:100% LOAD Ta:25°C	PASS
2	CONDUCTION	EN55022 CLASS B	I/P : 230 VAC (50HZ) O/P : FULL/50% LOAD Ta : 25°C	PASS Test by certified Lab
3	RADIATION	EN55022 CLASS A	I/P : 230 VAC (50HZ) O/P : FULL LOAD Ta : 25°C	PASS Test by certified Lab
4	E.S.D	EN61000-4-2 INDUSTRY AIR : 8KV / Contact : 4KV	I/P : 230 VAC/50HZ O/P : FULL LOAD Ta : 25°C	CRITERIA A
5	E.F.T	EN61000-4-4 INDUSTRY INPUT : 2KV	I/P : 230 VAC/50HZ O/P : FULL LOAD Ta : 25°C	CRITERIA A
6	SURGE	IEC61000-4-5 INDUSTRY L-N : 2KV L,N-PE : 4KV	I/P : 230 VAC/50HZ O/P : FULL LOAD Ta : 25°C	CRITERIA A
7	Test by certified Lab & Test Report Prepare			

■ **RELIABILITY TEST**

ENVIRONMENT TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT																																																																																																																																				
1	TEMPERATURE RISE TEST	MODEL : RCB-1600-24 1. ROOM AMBIENT BURN-IN : 1 HRS I/P : 230VAC O/P : FULL LOAD Ta= 28.3 °C 2. HIGH AMBIENT BURN-IN : 3 HRS I/P : 230VAC O/P : FULL LOAD Ta= 52.5 °C																																																																																																																																						
				<table border="1"> <thead> <tr> <th>NO</th> <th>Position</th> <th>ROOM AMBIENT Ta= 28.3 °C</th> <th>HIGH AMBIENT Ta= 52.5 °C</th> </tr> </thead> <tbody> <tr><td>1</td><td>Q901</td><td>48.6°C</td><td>72.3°C</td></tr> <tr><td>2</td><td>Q904</td><td>75.5°C</td><td>81.5°C</td></tr> <tr><td>3</td><td>Q52</td><td>63.2°C</td><td>87.8°C</td></tr> <tr><td>4</td><td>D50</td><td>68.9°C</td><td>99.6°C</td></tr> <tr><td>5</td><td>BD1</td><td>58.1°C</td><td>85.6°C</td></tr> <tr><td>6</td><td>L900</td><td>45.9°C</td><td>68.6°C</td></tr> <tr><td>7</td><td>T3</td><td>37.6°C</td><td>61.7°C</td></tr> <tr><td>8</td><td>RG301</td><td>53.9°C</td><td>81.7°C</td></tr> <tr><td>9</td><td>RG302</td><td>51.7°C</td><td>76.2°C</td></tr> <tr><td>10</td><td>C302</td><td>30.3°C</td><td>55.3°C</td></tr> <tr><td>11</td><td>C355</td><td>38.1°C</td><td>59.4°C</td></tr> <tr><td>12</td><td>T1</td><td>30.2°C</td><td>76.1°C</td></tr> <tr><td>13</td><td>Q101</td><td>47.8°C</td><td>76.0°C</td></tr> <tr><td>14</td><td>Q104</td><td>48.7°C</td><td>77.2°C</td></tr> <tr><td>15</td><td>U921</td><td>41.9°C</td><td>70.4°C</td></tr> <tr><td>16</td><td>C5</td><td>38.4°C</td><td>64.2°C</td></tr> <tr><td>17</td><td>L100</td><td>65.7°C</td><td>97.8°C</td></tr> <tr><td>18</td><td>C980</td><td>33.4°C</td><td>63.9°C</td></tr> <tr><td>19</td><td>C11</td><td>42.8°C</td><td>69.2°C</td></tr> <tr><td>20</td><td>ZNR1</td><td>46.0°C</td><td>70.9°C</td></tr> <tr><td>21</td><td>ZNR2</td><td>42.3°C</td><td>75.6°C</td></tr> <tr><td>22</td><td>LF1</td><td>43.8°C</td><td>69.7°C</td></tr> <tr><td>23</td><td>C2</td><td>43.0°C</td><td>69.7°C</td></tr> <tr><td>24</td><td>D2</td><td>42.9°C</td><td>65.1°C</td></tr> <tr><td>25</td><td>L1</td><td>49.1°C</td><td>77.9°C</td></tr> <tr><td>26</td><td>L2</td><td>51.0°C</td><td>79.1°C</td></tr> <tr><td>27</td><td>RY1</td><td>45.3°C</td><td>71.4°C</td></tr> <tr><td>28</td><td>C101</td><td>47.0°C</td><td>73.6°C</td></tr> <tr><td>29</td><td>T52</td><td>37.9°C</td><td>65.3°C</td></tr> <tr><td>30</td><td>RTH21</td><td>54.0°C</td><td>76.4°C</td></tr> <tr><td>31</td><td>RTH9</td><td>45.3°C</td><td>72.3°C</td></tr> <tr><td>32</td><td>U671</td><td>43.8°C</td><td>70.0°C</td></tr> </tbody> </table>	NO	Position	ROOM AMBIENT Ta= 28.3 °C	HIGH AMBIENT Ta= 52.5 °C	1	Q901	48.6°C	72.3°C	2	Q904	75.5°C	81.5°C	3	Q52	63.2°C	87.8°C	4	D50	68.9°C	99.6°C	5	BD1	58.1°C	85.6°C	6	L900	45.9°C	68.6°C	7	T3	37.6°C	61.7°C	8	RG301	53.9°C	81.7°C	9	RG302	51.7°C	76.2°C	10	C302	30.3°C	55.3°C	11	C355	38.1°C	59.4°C	12	T1	30.2°C	76.1°C	13	Q101	47.8°C	76.0°C	14	Q104	48.7°C	77.2°C	15	U921	41.9°C	70.4°C	16	C5	38.4°C	64.2°C	17	L100	65.7°C	97.8°C	18	C980	33.4°C	63.9°C	19	C11	42.8°C	69.2°C	20	ZNR1	46.0°C	70.9°C	21	ZNR2	42.3°C	75.6°C	22	LF1	43.8°C	69.7°C	23	C2	43.0°C	69.7°C	24	D2	42.9°C	65.1°C	25	L1	49.1°C	77.9°C	26	L2	51.0°C	79.1°C	27	RY1	45.3°C	71.4°C	28	C101	47.0°C	73.6°C	29	T52	37.9°C	65.3°C	30	RTH21	54.0°C	76.4°C	31	RTH9	45.3°C	72.3°C	32	U671	43.8°C	70.0°C
NO	Position	ROOM AMBIENT Ta= 28.3 °C	HIGH AMBIENT Ta= 52.5 °C																																																																																																																																					
1	Q901	48.6°C	72.3°C																																																																																																																																					
2	Q904	75.5°C	81.5°C																																																																																																																																					
3	Q52	63.2°C	87.8°C																																																																																																																																					
4	D50	68.9°C	99.6°C																																																																																																																																					
5	BD1	58.1°C	85.6°C																																																																																																																																					
6	L900	45.9°C	68.6°C																																																																																																																																					
7	T3	37.6°C	61.7°C																																																																																																																																					
8	RG301	53.9°C	81.7°C																																																																																																																																					
9	RG302	51.7°C	76.2°C																																																																																																																																					
10	C302	30.3°C	55.3°C																																																																																																																																					
11	C355	38.1°C	59.4°C																																																																																																																																					
12	T1	30.2°C	76.1°C																																																																																																																																					
13	Q101	47.8°C	76.0°C																																																																																																																																					
14	Q104	48.7°C	77.2°C																																																																																																																																					
15	U921	41.9°C	70.4°C																																																																																																																																					
16	C5	38.4°C	64.2°C																																																																																																																																					
17	L100	65.7°C	97.8°C																																																																																																																																					
18	C980	33.4°C	63.9°C																																																																																																																																					
19	C11	42.8°C	69.2°C																																																																																																																																					
20	ZNR1	46.0°C	70.9°C																																																																																																																																					
21	ZNR2	42.3°C	75.6°C																																																																																																																																					
22	LF1	43.8°C	69.7°C																																																																																																																																					
23	C2	43.0°C	69.7°C																																																																																																																																					
24	D2	42.9°C	65.1°C																																																																																																																																					
25	L1	49.1°C	77.9°C																																																																																																																																					
26	L2	51.0°C	79.1°C																																																																																																																																					
27	RY1	45.3°C	71.4°C																																																																																																																																					
28	C101	47.0°C	73.6°C																																																																																																																																					
29	T52	37.9°C	65.3°C																																																																																																																																					
30	RTH21	54.0°C	76.4°C																																																																																																																																					
31	RTH9	45.3°C	72.3°C																																																																																																																																					
32	U671	43.8°C	70.0°C																																																																																																																																					
2	LOW TEMPERATURE TURN ON TEST	TURN ON AFTER 2 HOUR	I/P : 230VAC/180VAC O/P : 100 % LOAD Ta= -35°C / -30°C	TEST : OK																																																																																																																																				
3	HIGH HUMIDITY HIGH TEMPERATURE HIGH VOLTAGE TURN ON TEST	AFTER 12 HOURS IN CHAMBER ON CONTROL 50 °C NO DAMAGE	I/P : 272 VAC O/P : FULL LOAD Ta= 50 °C HUMIDITY= 95 %R.H	TEST : OK																																																																																																																																				



4	TEMPERATURE COEFFICIENT	± 0.03 %/°C (0~50°C)	I/P : 230 VAC O/P : FULL LOAD	± 0.005 %/°C (0~50°C)
5	STORAGE TEMPERATURE TEST	1. Thermal shock Temperature : -45°C ~ +90°C 2. Temperature change rate : 25°C / MIN 3. Dwell time low and high temperature : 30 MIN/EACH 4. Total test cycle : 5 CYCLE 5. Input/Output condition : STATIC		OK
6	THERMAL SHOCK TEST	1. Thermal shock Temperature : -35°C ~ +55°C 2. Temperature change rate : 25°C / MIN 3. Dwell time low and high temperature : 30 MIN/EACH 4. Total test cycle : 10 CYCLE 5. Input/Output condition : 15cycle:230V/ FULL LOAD AC ON 3sec/AC OFF 1sec TEST(13500 TIMES) 1cycle:230V/ FULL LOAD Burn In Test		OK
7	VIBRATION TEST	1 Carton & 1 Set (1) Waveform : Sine Wave (2) Frequency : 10~500Hz (3) Sweep Time : 12min/sweep cycle (4) Acceleration : 2G (5) Test Time : 60min in each axis (X.Y.Z) (6) Ta : 25°C		TEST : OK
8	CAPACITOR LIFE CYCLE	SUPPOSE C101 IS THE MOST CRITICAL COMPONENT (1) I/P : 230VAC O/P : FULL LOAD Ta= 25°C LIFE TIME (2) I/P : 230VAC O/P : FULL LOAD Ta= 50°C LIFE TIME (3) I/P : 230VAC O/P : 75% LOAD Ta= 50°C LIFE TIME (4) I/P : 230VAC O/P : 50% LOAD Ta= 50°C LIFE TIME		(1) 781466HRS (2) 119480HRS (3) 179758HRS (4) 222934HRS
9	MTBF	Conducted by Parts Stress Analysis Prediction 476.7K hrs min. Telcordia SR-332 (Bellcore) ; 38.7K hrs min. MIL-HDBK-217F (25°C)		
10	DMTBF/Accelerated Life Test	Demonstration Mean Time Between Failure (Expected Life): Above 50,000 hours @ TA 50°C		

TEST RESULT	TESTER	REVIEW	APPROVAL
PASS	DANIEL GAO	SANFORD SU	VINCENT TSENG

12.10.30 A50-F031