

CERTIFICATE

Issued to:
Applicant:
MEAN WELL Enterprises Co., Ltd.
No.28, Wuquan 3rd Rd, Wugu District
24891 New Taipei City, Taiwan

Licensee:
MEAN WELL Enterprises Co., Ltd.
No.28, Wuquan 3rd Rd, Wugu District
24891 New Taipei City, Taiwan

Product : Independent LED driver
Trade name(s) : MEAN WELL
Type(s)/model(s) : XLG-20-H, XLG-20-H-B, XLG-20-L, XLG-20-L-B, XLG-20-M and XLG-20-M-B

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard(s) EN 61347-1:2015, EN 61347-1:2015/A1:2021, EN 61347-2-13:2014, EN 61347-2-13:2014/A1:2017, EN 62384:2006 and EN 62384:2006/A1:2009
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 2175773


DEKRA hereby grants the right to use the ENEC certification mark.

The ENEC certification mark may be applied to the product as specified in this certificate for the duration and under the conditions of the ENEC certification agreement.

This certificate is issued on 8 February 2022 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 35-122335

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



K. Lin
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: Independent LED driver
Trade name(s)	: MEAN WELL
Type(s)/model(s)	: XLG-20-H, XLG-20-H-B, XLG-20-L, XLG-20-L-B, XLG-20-M and XLG-20-M-B
Rated input voltage	: 100-277 V~
Rated input current	: 0,3 A
Rated frequency	: 50/60 Hz
Max. case temperature (tc)	: 80 °C
Ambient temperature (ta)	: 60 °C
Power factor	: 0,95
Class of insulation	: Class I
Additional information	: SELV Independent controlgear, non-inherently short-circuit proof, 110 °C thermal protection, MM mark

Product data – type XLG-20-H and XLG-20-H-B

Output Voltage	: max.40 Vdc, 18-30 Vdc
Output current	: 0,7 A
Rated power	: 21 W

Product data – type XLG-20-L and XLG-20-L-B

Output Voltage	: max.60 Vdc, 32,4-54 Vdc
Output current	: 0,35 A
Rated power	: 18,9 W

Product data – type XLG-20-M and XLG-20-M-B

Output Voltage	: max.50 Vdc, 25,2-42 Vdc
Output current	: 0,5 A
Rated power	: 21 W

TESTS**Test requirements**

EN 61347-1:2015
EN 61347-1:2015/A1:2021
EN 61347-2-13:2014
EN 61347-2-13:2014/A1:2017
EN 62384:2006
EN 62384:2006/A1:2009

Test result

The test results are laid down in DEKRA test file 438227700.

Additional information

The list of components is laid down in test report 4382277.50.

Conclusion

The examination proved that all requirements were met.

Factory locations

YONGDEN TECHNOLOGY CORPORATION

345 MacArthur HighWay Tabang,

3015 Guiguinto, Bulacan, The Philippines

MEAN WELL (GUANGZHOU) Electronics Co., Ltd.

No.11 Jingu South Road, Huadu District,

510890 Guangzhou Guangdong, China

Trade name(s) : MEAN WELL stands for

